

Hydrant Inspection Report

Docket No. 01-0492

ICC Staff Exh. 3.00

Schedule 3.01

System: Wonder Lake Water Company

pg. 1 of 2

Hydrant #	Location	1997	2001	Comments
		Gals. per min.	Gals. per min.	
16	Near Ridge Rd. & Acorn Path	630	790	a) Increase height of hydrant (18" to middle of Cap) COMPLETED b) Hydrants requires painting;
17	Westwood Dr. & Coral Rd.	630	920	a) Hydrants requires painting;
18	West Lake Shore Dr. & Acorn	630	700	a) Hydrant needs replacing; Hard to open & shakes when in operating
15	Between Alden & Coral on Greenwood Drive	580	800	
14	Between Alden & Dorr on Woodstock	770	840	a) Hydrant requires painting;
13	Between Alden & Dorr on Westwood Dr.			a) Hydrant needs replacing; does not operate COMPLETED
10	Between Burton & Dorr on Greenwood Dr.	730	820	a) Hydrant requires painting;
12	Ridge Road		700	Increase height of hydrant (18" to middle of cap)
11	Between Alden & Dorr on Thompson Rd.	650	No Flow test	a) Hydrant requires painting; COMPLETED
8	Burton Road & Ridge Drive	690	840	a) Hydrant requires painting; COMPLETED b) Hydrant hard to operate.

Note: No change from last inspection

Hydrant Inspection Report

Docket No. 01-0492

ICC Staff Exh. 3.00

Schedule 3.01

System: Wonder Lake Water Company

pg. 2 of 2

Hydrant #	Location	1997	2001	Comments
		Gals. per min.	Gals. per min.	
6	Riley Road	760	1000	a) Hydrant requires repair- Hard to operate (operated by hydrant valve)
9	West Lake Shore Dr. & Nunda Rd.	730	700	a) Hydrant requires replacing-does not shut off. REPAIRED
4	Between Garrison Rd. & Greenwood Dr. on West Lake	630	700	
7	Between Riley Rd. & Garrison Rd. on Greenwood Dr.	630	920	b) Hydrant chains needs fixing. COMPLETED
5	Garrison Road.	630	840	a) Hydrant requires painting;
1	West Lake Shore dr.	630	650	a) Hydrant requires painting;
2	Westwood Dr. (4107)		840	a) Replace hydrant - cracked barrel;
				b) Hydrant requires painting; COMPLETED
3	Westwood Dr. (4125)		840	a) Increase height of hydrant (i8" to middle of cap).
				a) Hydrant requires painting;
FV 10				Replaced with hydrant, installed 12-04 -01

NO change from last inspection

ComEd

Chicago Edison

007277



** BOO2

WONDER LAKE WATER CO
PO BOX 189
WONDER LAKE, IL 60097

Residential Customers, *

1-800-Edison-

Docket No. 01-0492
ICC Staff Exhibit 3.0
Schedule 3.02 (a)

04292



Account Number
0429213007

Payment Amount



ComEd
8111 Payment Center
Chicago IL 60668-0001

00000009120000603768

042921300700092090420179209047

Return this portion with your check made payable to ComEd. Please write your account number on your check.

When paying in person, please bring the entire bill.

Page 1
Name

WONDER LAKE WATER CO

04292 1300 70002 0177

Service Location 8519 ALDEN RD, WONDER LAKE
Phone Number -



Account Number 0429213007
Issue Date 11/30/2001

Meter Information	Read Date	Meter Number	Load Type	Reading Type	Meter Reading		Diff	Mult x	Usage
					Previous	Present			
	11/30	997125181	Pumping	On Pk kW	ACT	ACT			19.49
	11/30	997125181	Pumping	Tot kWh	ACT	ACT			57

Current Period

Water and Sewage Pumping Service
Customer charge
Energy charge
Decommissioning adjustment
Instrument Funding Charge Credit
Instrument Funding Charge Debit
State tax
Total current charges

Service from 10/30/2001 to 11/30/2001 - 31 Days

57 kWh X	\$4.50
57 kWh X	4.39
57 kWh X	0.0078
57 kWh X	-0.00396
57 kWh X	0.00396
	0.23
	0.19

\$9.12